

TÜRKAK
TÜRK AKREDİTASYON KURUMU



TURKISH ACCREDITATION AGENCY
tarafından akredite edilmiştir

EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.

TOSB TAYSAD Organize San. Böl. 1. CD. ,15. Yol No: 1
Şekerpınar – Çayırova, KOCAELİ

AB-0556-T

03.09.2014

RFTR14030

DENEY RAPORU

TEST REPORT

| | | |
|---|---|--|
| Müşterinin adı/adresi <i>Customer name/address</i> | : | MESA, KANTUR-AKDAŞ, ARTAŞ, ÖZTAŞ ORTAKLIĞI 842 Ada 58 Parsel Atakent- Halkalı, Küçükçekmece İSTANBUL / TURKEY |
| İstek numarası <i>Order No.</i> | : | EEA-14-000164 |
| Numunenin adı ve tarifi <i>Name and identity of test sample</i> | : | Single Leaf Fire Exit Door with Corner Frame - 90 x 210 cm |
| Numunenin kabul tarihi <i>The date of receipt of sample</i> | : | 15.07.2014 |
| Açıklamalar <i>Remarks</i> | : | |
| Deneyin yapıldığı tarih <i>Date of test</i> | : | 21.07.2014 |
| Raporun sayfa sayısı <i>Number of pages of the Report</i> | : | 20 (Totally 31 pages with annexes) |

Türk Akreditasyon Kurumu(TÜRKAK) deney raporlarının tanınması konusunda Avrupa Akreditasyon Birliği(EA) ve Uluslararası Laboratuvar Akreditasyon Birliği(ILAC) ile karşılıklı tanınma antlaşmasını imzalamıştır.

The Turkish Accreditation Agency(TURKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation(EA) and of the International Laboratory Accreditation(ILAC) for the Mutual recognition of test reports

Deney ve /veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metotları bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report

Mühür

Seal



Tarih

Date

03.09.2014

Deney Sorumlusu

Person in charge of test

Burak ACİCBE

Laboratuvar Müdürü

Head of Testing Laboratory

Onur DAĞ

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

1. SCOPE

Fire resistance test, in conformity with the general requirements of standards TS EN 1363-1, with substitute or additional methods of standard TS EN1363-2 and with the particular requirements of standard TS EN 1634-1 "Fire resistance and smoke control tests for door, shutter and openable window assemblies and elements of building hardware - Part 1: Fire resistance tests for doors, shutters and openable windows", only exception of the conditioning requirements that is mention in Annex A of TS EN 1634-1 .

2. TEST LABORATORY

Name : Efectis Era Avrasya Test ve Belgelendirme A.Ş.
Address : TOSB TAYSAD Organize San. Böl. 1. CD. ,15. Yol No: 1
Şekerpınar – Çayırova, KOCAELİ / TURKEY

3. DESCRIPTION OF THE TEST SPECIMEN**3.1. General**

Product identification : Single Leaf Fire Exit Door with Corner Frame - 90 x 210 cm

Direction of fire : Hinges away from fire

Manufacturer : CMD METAL ÇELİK KAPI VE YANGIN KAPISI İNŞ. PAZ. SAN. VE DIŞ TİC. LTD. ŞTİ.
İOSB Atatürk San. Sit. 2. Sokak No:27/28 Başakşehir İSTANBUL/TURKEY

Sponsor of test : MESA, KANTUR-AKDAŞ, ARTAŞ, ÖZTAŞ ORTAKLIĞI
842 Ada 58 Parsel Atakent- Halkalı, Küçükçekmece İSTANBUL / TURKEY



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

3.2. Construction

A side opening steel door construction, "Single Leaf Fire Exit Door with Corner Frame - 90 x 210 cm" was mounted in a masonry supporting construction, made of aerated concrete blocks with the mounting clearances dimensions of 990 x 2100 mm (w x h).

The supporting construction was supplied by the test laboratory (Efectis Era Avrasya) and consisted of aerated concrete blocks which have a density of 450 kg/m³ and thickness of 200 mm. The sponsor of the test was applied wall plaster (GESEREPAR 730) to the un exposed surface of the supporting construction.

3.3. Components

3.3.1. Door Frame:

The frame studs and header were welded to each other. Wall plaster was filled between the supporting construction and the frame. Intumescent seal was used at the contact points of the door frame and the leaf. The frame was supported by anchorage plates and fixed to supporting construction by steel bolts.

- **Type** : Shaped from DKP steel plate.
- **Dimensions** :
 - Frame studs : 16/35 x 76 x 2100/2142 mm (w x d x h)
 - Frame header : 16/35 x 76 x 910/1083 mm (w x d x h)
 - Wall thickness of the steel plate : 1,5 mm.
- **Seal** :
 - Type : Intumescent seal strip – Intuflex ORBIS
 - o Dimensions : 2 x 20 mm (t x w)
 - o Locations : Contact points of the leaf and frame.
- **Filler** :
 - Type : Wall plaster – GESEREPAR 730
 - o Measured density : 1900 kg/m³
 - o Nominal thickness : 3 ± 1 mm
- **Fixing** :
 - Type : Steel bolt
 - o Dimensions : M8 X 160 (Ø x l)
 - o Location : 3 pcs at each stud (250 and 1075 mm from top of the leaf and 250 mm from bottom of the leaf), 2 pcs at the header (250 mm from each leaf corner).
- **Reinforcement:**
 - Type : Anchorage plate
 - o Dimensions : 50 x 150 x 3 (d x w x t)
 - o Locations : 2 pcs at each stud.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



See figures 1-5 for details.

3.3.1.1. Leaf:

The leaf was covered by steel plates with insulation inside. Between two layers of gypsum board, stone wool was used. Intumescent seal was used at contact points of the leaf and the frame. The leaf supported by Ω steel profiles.

- **Covering plate** : DKP steel plate, wall thickness; 0,8 mm.
- **Dimensions** : 900/1015 x 2100/2113 x 58 mm (w x h x t).
- **Insulation** :
 - **Type** : Gypsum board – ATIŞKAN
 - Nominal thickness : 12 + 12 mm (2 layers.)
 - Mass per unit area : Less than 10 kg/m²
 - Fire classification according to EN 13501-1: A2-s1,d0
 - Mass per unit area of paper facing: Less than 200 gr/m²
 - **Type** : Stone wool – WOOLER
 - Nominal density : 40 kg/m³
 - Nominal thickness : 32 mm
- **Seal** :
 - **Type** : Intumescent seal strip – Intuflex ORBIS
 - Dimensions : 2 x 20 mm (t x w)
 - Locations : Contact points of the leaf and frame.
- **Reinforcement:**
 - **Type** : Ω shaped steel profile
 - Dimensions : 32 x 120 x 1 mm (w x l x t)
 - Locations : 2 pcs inside the leaf. See figure 6.

See figures 2-4 for details.

3.3.1.2. Accessories:

- **Hinges** :

The leaf was hung on two steel hinges.

- **Type** : Steel Spring Hinge – MCMD 1001-01 – CMD - DEMİROĞLU
 - Dimensions : 27 x 170 mm (\varnothing x l)
 - Locations : 170 and 1842 from top of the frame.
- See figure 7.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



- **Panic bar** :
 - **Type** : PBDMR 1001-3 – CMD - DEMİROĞLU
 - **Location** : 1000 mm from the bottom of the door sill.
See figure 2.
- **Door handle:**
 - **Type** : Anti-panic handle – MUL-T-LOCK
 - **Location** : 936,3 mm from the bottom of the door sill.
- **Lock:**
 - **Type** : Mortised lock – NEMEF - 1739
 - **Location** : 886 mm from the bottom of the door sill.
- **Fire lock: Provides fixing between the leaf and the frame by self-closing when heated.**
 - **Type** : YKCMD 1001-02 – CMD - DEMİROĞLU
 - **Location** : 2 pcs., on the leaf at top and bottom of the lock side.
See figure 8.

See figure 1-8 for details.

4. PRE-TEST PROCESSES

4.1. Verification of specimen

Efectis Era Avrasya A.S. verified the used materials and parts against the supplied data and drawings during installation of the test specimen and not involved in the selection of test specimen.

The test specimen was assembled by the manufacturer (CMD METAL ÇELİK KAPI VE YANGIN KAPISI İNŞ. PAZ. SAN. VE DIŞ TİC. LTD. ŞTİ.).




Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

4.2. Gap measurements



| | A | B | C | D | E | F | G | H | I | J |
|--------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| First | 9,0 | 7,0 | 3,0 | 4,0 | 4,0 | 6,0 | 8,0 | 4,0 | 4,0 | 3,5 |
| Middle | 7,0 | 6,0 | 5,0 | 6,0 | 6,0 | 6,0 | 7,0 | 5,0 | 5,0 | 4,0 |
| Third | 7,0 | 8,0 | 6,0 | 3,0 | 6,0 | 5,0 | 6,0 | 6,0 | 1,5 | 1,5 |

Dimensions in mm.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



4.3. Self-closing test

The functionality tests of the doors have been made before the fire resistance test by both laboratory and customer.

Closing force of the leaf of doorset: 58N

The leaves of doors were submitted to 25 opening/closing operations under normal speed. No visible disorder was noted after this test.

4.4. Direction of fire

The test was performed with hinges turning away from fire.

4.5. Conditioning

From the moment of installation until the fire resistance test, the construction was stored in the laboratory of Efectis Era Avrasya A.S. under the following conditions:

Temperature : $30,3 \pm 2,7^{\circ}\text{C}$
Relative humidity : $50 \pm 9 \%$.

5. TEST PROCESS

5.1. Method

The fire test was conducted according to the TS EN 1634-1.

The heating of the furnace followed the standard fire curve, as specified in the TS EN 1363-1.

The target overpressure in the furnace was 0 Pa at 500 mm above floor level and 20 Pa at the top of the test specimen.

5.2. Measurements

Following test data were measured during the test:

- Ambient temperatures inside the furnace with six plate thermocouples (Furnace TC1 to Furnace TC6), evenly distributed over the directly heated surface (see figure A1).
- The pressure in the furnace, measured at sill level and a height of 2,7 meter above the furnace floor level (see figure A3).
- Ambient temperature in the laboratory (see figure A4).
- The surface temperatures on the unexposed side of the test specimen (TC21 up to TC38), see figure B2).
- There was no need to use roving thermocouple
- The deformation of the test specimen (See Figure B3 and Table B1)

The positions of the thermocouple and displacement measurements are given in figure B1.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



6. OBSERVATIONS

Table 1: Observations during heating.

| | |
|----|---|
| 0 | Heating started. See figure C1-C2 . |
| 4 | Smoke release between the door frame and the leaf. |
| 6 | Deformation at top and bottom edges between the door frame and the leaf. |
| 12 | F – Panic bar of the door dropped. |
| 17 | Opening between the door frame and the leaf at the top. |
| 51 | Temperature increased at Thermocouple Nr. 35, $\Delta T > 180$ °C. I₁ failed for the Door. |
| 57 | Falling parts of the seal from the top. |
| 62 | Smoke release from the bottom of the door. |
| 73 | Opening between the door frame and the leaf at the hinge side. |
| 80 | Opening increased between the door frame and the leaf at the hinge side. |
| 83 | Cotton pad was applied to the opening between the door frame and the leaf at the hinge side. No ignition. |
| 86 | Cotton pad was applied to the opening between the door frame and the leaf at the hinge side. No ignition. |
| 89 | Cotton pad was applied to the opening between the door frame and the leaf at the hinge side. No ignition. |
| 93 | Cotton pad was applied to top of the lock side between the frame and supporting construction. Ignition. Integrity failed for the Door. |
| 94 | Test was terminated after consulted with the sponsor. See figure C3-C4 . |

F: Furnace side (exposed surface)

7. TEST RESULTS**7.1 Results**

The results are given in Table 2 and appendixes B and C.

During the heating the temperature in the laboratory complied with the TS EN 1363-1.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



7.2 Uncertainty of measurements

Due to the nature of fire resistance testing, in which several non-linear effects are present in both the test configuration and the test specimen, which influence each other, it is at this moment not yet possible to give a stated degree of uncertainty of measurement.

8. SUMMARY

The most important results of the examination are given in table 2.

Table 2: Summary of test results of the test specimen

| | Results |
|--|--|
| Integrity, (E) – Cotton pad – Gap gauges \varnothing 6 mm \varnothing 25 mm – Flames longer than 10 sec. | 93 rd minute, no failure (not applied) no failure (not applied) not observed. |
| Insulation:, [I] – average temperature – maximum temperature | 93 rd minute (due to the failure of integrity) 51 st minute by TC 35 for I_1 , 93 rd minute (due to the failure of integrity) for I_2 . |
| Test was terminated at 94 th minute after consulted with sponsor. | |

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



9. FIELD OF DIRECT APPLICATION OF TEST RESULTS

9.1 General

This report details the method of construction, the test conditions and the results obtained when the specific elements of construction described herein was tested following the procedure outlined in TS EN 1363-1, and when appropriate TS EN 1363-2. Any significant deviation with respect to size, constructional details, load stresses, edge or end conditions other than those allowed under the field of direct application in the relevant test method is not covered by this report.

Except if otherwise specified hereafter, the design of the door-unit shall be identical to that of the test specimen. It is not allowed to modify the number of door leaves and the operating mode (e.g. swing door or pivoted door, single or double acting door).

9.2 Specific Restrictions Concerning Materials and Structures

9.2.1. Metal structures

It is allowed to increase the steel envelope around the fixed frames in order to allow for thicker supporting structures. It is allowed to increase the steel thickness by 25 % maximum.

It is not allowed to change type of the metal.

The number of stiffening elements for doors without thermal insulation and the number and the type of their attachments in the panel manufacture may be increased in proportion to the increase of the dimensions, but it is not allowed to be reduced.

9.2.2. Decorative coatings

9.2.2.1. Paint

Electrostatic powder painting is allowed for the surfaces of the door frames. Any painting is not allowed on the hardware components and on the surfaces of door leaves.

9.2.2.2. Decorative laminate

Decorative laminates and timber veneers up to 1,5 mm thickness are allowed to be added to the faces (but not the edges) of leaves and frames in doorsets which satisfy the insulation criteria (Allowed for only: EI₄₅, EI₉₀).

9.2.3. Fixings

It is permitted to increase the number of fasteners used to attach the fire resistant doors onto the supporting structures but it is not allowed to be reduced, and it is allowed to reduce the distance between the fasteners but it is not allowed to be increased.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



9.2.4. Hardware

It is allowed to increase the number of movement-limiting devices such as locks, bolts and hinges but it is not allowed to be reduced.

9.3 Permissible Size Variations

9.3.1 General

Doors with dimensions which are different from those of the test specimens shall be permitted within some extent, but variations depend on the type of product and on the time during which the fire resistance criteria are met.

The increase and decrease of dimensions permitted by the field of direct application are applicable to the overall size of each leaf, each side panel, each transom panel and each over panel independently and including ant rebates which may be present on the leaf or panel.

The limits of permitted size variation are given in Annex B of the standard TS EN 1634-1.

9.3.2 Dimension variations according to the type of product

9.3.2.1. Permissible dimension variations of the leaf

The amount of variation of size permitted is dependent on whether the classification time was just reached (category 'A') or whether an extended time (category 'B' overrun) in accordance with the following values was fulfilled before the test was concluded.

| Classification time | All performance criteria fulfilled for at least |
|---------------------|---|
| 15 minutes | 18 minutes |
| 20 minutes | 24 minutes |
| 30 minutes | 36 minutes |
| 45 minutes | 52 minutes |
| 60 minutes | 68 minutes |
| 90 minutes | 100 minutes |

Consequently, increase of the dimension is only valid in case of related performance about "Category B overrun" is achieved in Clause 8, Table 2.

The 'Category A' and 'Category B' classification of the sample 'Single Leaf Fire Exit Door with Corner Frame - 90 x 210 cm' is given in the classification report (EEA – 14 – 021).

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



a) Category A classification:

Due to the Category A classification of Door, no size increase is allowed. The reduction of the metal doorsets is limited at %75 in height and % 50 in width.

b) Category B classification:

| Overall dimension of the leaf | Min. | Max. |
|-------------------------------|------------------|----------------------------|
| Height | 525 mm (% 75) | 2415 mm (%15) |
| Width | 450 mm (% 50) | 1035 mm (%15) |
| Area | - | 2,268 m ² (%20) |

Size increases are only allowed for the doorsets provided that used with the gaps indicated in the table below:

| | Average measured | Maximum measured | Practical maximum allowed |
|----------|------------------|------------------|---------------------------|
| A | 7,7 | 9,0 | 10,35 |
| B | 7,0 | 8,0 | 9,5 |
| C | 4,7 | 6,0 | 7,35 |
| D | 4,3 | 6,0 | 7,15 |
| E | 5,3 | 6,0 | 7,65 |
| F | 5,7 | 6,0 | 7,85 |
| G | 7,0 | 8,0 | 9,5 |
| H | 5,0 | 6,0 | 7,5 |
| I | 3,5 | 5,0 | 6,25 |
| J | 3,0 | 4,0 | 5,5 |

9.3.2.2. Other changes

For doors with smaller dimensions, the relative position of the movement-limiting devices (e.g. hinges, bolts, etc.) shall remain identical to that of the test specimen, or any modification in the distance between them shall be limited to the same reduction percentage as the dimension reduction of the test specimen.

It is not allowed to change the relative position of the movement-limiting devices (Hinges, bolts, etc.). It is permitted to modify the distance with the same percentage for the reduction of the test specimen.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

For larger doorset sizes the following also must be applied (Category B):

- 1) The height of the latch above floor level must be equal to or greater than the tested height, and the maximum of any change in height must be proportional to the increase in doorset height;
- 2) The distance of the top hinge from the top of door leaf must be equal to or less than that tested;
- 3) The distance of the bottom hinge from bottom of door leaf must be equal to or less than that tested.
- 4) For three hinges or distortion preventers are used, the distance between bottom of the door leaf and centre restraint must be equal to or greater than tested.

9.4 Direction of Fire

The fire resistance behaviour specified in section 8 of this test report shall be valid for only the following direction of fire:

- Integrity : Opening away from the fire and towards the fire
- Thermal insulation : Opening away from the fire.

9.5 Supporting Construction

Rigid block with a density of at least 450 kg/m³, having a thickness of at least 200 mm. It is not allowed to change surface coating that used at unexposed side of supporting construction.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid






Figure 2: Exposed side view of the Door.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid






Figure 3: Detailed cross section of the Door.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.
İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

YAN GÖRÜNÜŞ/SIDE VIEW



Figure 4: Side view of the Door.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.
İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



KASA DETAYI/DETAILS OF THE FRAME




Figure 5: Details of the frame.

**OMEGA DESTEK SACI
OMEGA SUPPORTING PLATE**




Figure 6: Details of the omega supporting profile

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid







Figure 7: Details of the hinge



yangın kılıdı/fire lock

YKCMD 1001-02

ısı ulastığında
kendiliginden kapanan
kilit/ self-closing lock by
heat

Figure 8: Details of the fire lock

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



APPENDIXES:

Appendix A: Furnace and laboratory conditions

Appendix B: Test results

Appendix C: Photos

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid






Figure A1: Furnace Temperatures.




Figure A2: Deviation of furnace temperature.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure A3: Pressure in the furnace.




Figure A4: Ambient temperature at laboratory.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid






Figure B1: Locations of thermocouples and deflection sensors.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid






Figure B2: Surface temperatures of Door.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B3: Deformation of the test specimen.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



Table B1: Data obtained from deformation sensors.

| Time (min) | Def. 1 (mm) | Def. 2 (mm) | Def. 3 (mm) | Def. 4 (mm) | Def. 5 (mm) | Def. 6 (mm) |
|------------|-------------|-------------|-------------|-------------|-------------|-------------|
| 0,0 | -0,05 | -0,05 | 0,00 | 0,30 | -0,03 | 0,00 |
| 2,0 | 0,05 | -3,78 | -3,53 | 0,30 | -8,03 | -0,23 |
| 4,0 | 0,05 | -6,18 | -7,93 | 0,30 | -14,13 | -0,58 |
| 6,0 | 0,08 | -7,48 | -10,40 | 0,28 | -17,60 | -0,73 |
| 8,0 | -0,30 | -8,98 | -13,00 | 0,30 | -20,25 | -1,08 |
| 10,0 | -2,48 | -9,78 | -13,65 | 0,30 | -21,15 | -1,68 |
| 12,0 | -4,05 | -10,08 | -13,65 | 0,30 | -21,63 | -2,28 |
| 14,0 | -5,73 | -10,45 | -14,13 | 0,30 | -22,23 | -2,78 |
| 16,0 | -7,93 | -10,45 | -14,15 | 0,30 | -22,55 | -2,93 |
| 18,0 | -9,20 | -10,45 | -14,53 | 0,30 | -23,00 | -3,20 |
| 20,0 | -9,25 | -10,48 | -14,88 | 0,30 | -23,38 | -3,53 |
| 22,0 | -9,25 | -10,45 | -14,88 | 0,30 | -23,70 | -3,55 |
| 24,0 | -9,23 | -10,45 | -15,55 | 0,30 | -24,15 | -3,53 |
| 26,0 | -9,23 | -10,40 | -15,85 | 0,28 | -24,50 | -3,60 |
| 28,0 | -9,25 | -10,38 | -16,50 | 0,30 | -24,78 | -3,63 |
| 30,0 | -9,23 | -10,38 | -16,78 | 0,30 | -24,93 | -3,65 |
| 32,0 | -9,23 | -10,38 | -16,93 | 0,28 | -25,05 | -3,70 |
| 34,0 | -9,50 | -10,40 | -17,08 | 0,30 | -25,20 | -3,70 |
| 36,0 | -10,23 | -10,38 | -17,08 | 0,30 | -25,33 | -3,83 |
| 38,0 | -10,95 | -10,40 | -17,10 | 0,28 | -25,45 | -3,85 |
| 40,0 | -11,68 | -10,43 | -17,48 | 0,28 | -25,68 | -3,95 |
| 42,0 | -12,13 | -10,43 | -17,48 | 0,28 | -25,78 | -3,95 |
| 44,0 | -12,68 | -10,43 | -17,55 | 0,28 | -26,00 | -4,03 |
| 46,0 | -13,10 | -10,43 | -17,93 | 0,23 | -26,23 | -4,15 |
| 48,0 | -13,50 | -10,88 | -18,15 | 0,23 | -26,53 | -4,30 |
| 50,0 | -13,83 | -10,85 | -18,18 | 0,25 | -26,80 | -4,38 |
| 52,0 | -14,13 | -10,88 | -18,18 | 0,20 | -27,20 | -4,50 |
| 54,0 | -14,38 | -11,05 | -18,18 | 0,18 | -27,53 | -4,55 |
| 56,0 | -15,00 | -11,60 | -19,00 | -0,30 | -28,18 | -5,15 |
| 58,0 | -15,18 | -11,60 | -19,00 | -0,30 | -28,53 | -5,15 |
| 60,0 | -15,53 | -11,60 | -19,60 | -0,43 | -28,98 | -5,15 |
| 62,0 | -15,83 | -11,63 | -19,85 | -0,65 | -29,58 | -5,38 |
| 64,0 | -16,18 | -11,65 | -19,83 | -0,65 | -29,93 | -5,38 |

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.
İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



| Time (min) | Def. 1 (mm) | Def. 2 (mm) | Def. 3 (mm) | Def. 4 (mm) | Def. 5 (mm) | Def. 6 (mm) |
|------------|-------------|-------------|-------------|-------------|-------------|-------------|
| 66,0 | -17,08 | -12,15 | -21,03 | -1,43 | -31,23 | -6,13 |
| 68,0 | -17,40 | -12,55 | -21,10 | -1,43 | -31,80 | -6,13 |
| 70,0 | -17,48 | -12,48 | -21,13 | -1,43 | -32,15 | -6,10 |
| 72,0 | -17,55 | -12,48 | -21,13 | -1,43 | -33,03 | -6,10 |
| 74,0 | -17,65 | -12,50 | -21,13 | -1,43 | -33,90 | -6,10 |
| 76,0 | -17,65 | -12,50 | -21,13 | -1,45 | -34,95 | -6,30 |
| 78,0 | -17,90 | -12,85 | -21,13 | -1,45 | -35,98 | -6,43 |
| 80,0 | -18,40 | -13,05 | -21,15 | -2,38 | -37,05 | -6,58 |
| 82,0 | -18,75 | -13,48 | -21,20 | -2,55 | -37,80 | -6,80 |
| 84,0 | -18,98 | -13,78 | -21,40 | -2,55 | -38,65 | -7,05 |
| 86,0 | -18,98 | -14,03 | -21,40 | -2,55 | -39,10 | -7,33 |
| 88,0 | -18,98 | -14,53 | -21,55 | -2,60 | -39,65 | -7,48 |
| 90,0 | -18,95 | -14,83 | -21,55 | -2,63 | -40,10 | -7,90 |
| 92,0 | -18,98 | -15,08 | -21,58 | -2,63 | -40,33 | -8,10 |

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid






Figure C1: Unexposed side of the test specimen before the test.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid






Figure C2: Exposed side of the test specimen before the test.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid





Figure C3: Unexposed side of the test specimen after the test.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid





Figure C4: Exposed side of the test specimen after the test.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

